

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Shri. Ramesh G. Metri

(Name of Officers with designation) from Shri. Ramesh G. Metri PHED

inspected the Assistant Executive Engineer

(Name & Address of the school) on 04/9/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 285 dated 28/08/2025

of - (PHED Lab) certified that the

Honeywell Int Eng med / Primary School Parishwad (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 12 monthly

Signature with Seal: Shri. Ramesh G. Metri

Name: Ramesh G. Metri

Designation: Assistant Executive Engineer

Name & Address of the Office / Department: RDWS&S sub division Khanapur

To: The Principal
Honeywell Int English
medium Primary School Parishwad
(Name & Address of the Institution)

RDWS&S sub division Khanapur
Tq:- Khanapur
Dt:- Belagavi

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Belagavi District Drinking water Quality Testing Laboratory
Rural Drinking Water and Sanitation Department
PRED Building Near Nehru Nagar , Krishndevaraya circle Belagavi -590010
Email-rdwsd.wqmspbelagavi@gmail.com/ee.rws.bgm@gmail.com Ph no:- 0831-2420835/2420836

TEST REPORT

District : Belagavi	Report date: 29-08-2025
Taluka : Khanapur	Report Number:-285
GramPanchayath: Parishwad	Reference: Sample receipt Form
Village : Parishwad	Sample receipt date: 28-08-2025
Source Location : Honeywell International ENG MED Jr./SR.PRI.School.Sy.No 06,Khanapur road,Parishwad	Date of Sample collection: 28-08-2025 Analysis start date: 28-08-2025 Analysis completion date: 29-08-2025 Sample collection protocol: APHA 24 th Method

Sample Particulars:Water from Purification Plant Sample quantity:1 LITRE

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
-------	------	---------	--	---	----------

Description: Colourless Liquid					
1.	pH Value at 25°C	7.21 @25°C	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Specific Conductance at 25°C,µS/cm	289 @25°C	-	-	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
5.	Colour, Hazen Units	5	5	15	IS 3025 (Part-4) :2021
6.	Turbidity, NTU	1.1	1	5	IS 3025 (Part-10) : 2023
7.	Total Dissolved Solids at 180°C, mg/l	172 @180°C	500	2000	IS 3025 (Part-16) : 2023
8.	Alkalinity as CaCO ₃ , mg/l	102.44	200	600	IS 3025 (Part-23) : 2023
9.	Total Hardness as CaCO ₃ , mg/l	101.09	200	600	IS 3025 (Part-21) : 2009
10.	Calcium as Ca, mg/l	25.91	75	200	IS 3025 (Part-40) : 1991
11.	Magnesium as Mg, mg/l	8.84	30	100	IS 3025 (Part-46) : 2023
12.	Chloride as Cl, mg/l	41.09	250	1000	IS 3025 (Part-32) : 1988
13.	Sulphate as SO ₄ , mg/l	5.76	200	400	IS 3025 (Part-24) : 2022
14.	Fluoride as F, mg/l	0.44	1	1.5	APHA 24 th Method
15.	Nitrate as NO ₃ , mg/l	11.36	45	No relaxation	APHA 24 th Method
16.	Iron as Fe, mg/l	0.21	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks: In the given sample Turbidity Confirms Permissible Limit,where as the other tested parameters Confirms acceptable limit as per IS 10500-2012 Drinking water specification.

Reviewed by: Junior Analyst  Authorized Signatory: Technical Manager 

RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01.

-----End Of Report-----



ಕರ್ನಾಟಕ ಸರ್ಕಾರ

ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ ಇಲಾಖೆ
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರವರ ಕಚೇರಿ, ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ
ಉಪ ವಿಭಾಗ, ಖಾನಾಪೂರ

ಪಂ.ರಾ.ಇಂ.ಉಪ ವಿಭಾಗ ಕಚೇರಿಯ 1ನೇ ಮಹಡಿ, ಖಾನಾಪೂರ-591302

E-mail : aeerwssknp@gmail.com

Phone : 08336 -200208

ನಂ:ಸಕಾನಿಅ/ಗ್ರಾಕುನೀ&ನೈ/ಉವಿ/ಖಾ/2025-26/ 266

ದಿನಾಂಕ:- 25/09/2025

ಇವರಿಗೆ,

Honeywell International Eng MED

JR./SR. PRI. School

Sy.No. 6, Khanapur Road

Parishwad - 591131

Tq:Khanapur Dist:Belgavi

ಮಹನೀಯರೇ,

ವಿಷಯ:-ಕುಡಿಯುವ ನೀರಿನ ಗುಣಮಟ್ಟದ ಪರೀಕ್ಷಾ ವರದಿಯನ್ನು ನೀಡುವ ಕುರಿತು.

ಉಲ್ಲೇಖ:-ತಮ್ಮ ಶಾಲೆಯ ಪತ್ರ ನಂ: HW15/OG/2435/ Dated: 08-09-2025

ಮೇಲ್ಕಾಣಿಸಿದ ವಿಷಯ ಹಾಗೂ ಉಲ್ಲೇಖಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ ಖಾನಾಪೂರ ತಾಲೂಕಿನ

Honeywell International Eng MED JR./SR. PRI. School ಶಾಲೆಯ ಕುಡಿಯುವ ನೀರಿನ

ಗುಣಮಟ್ಟದ ಪರೀಕ್ಷಾ ವರದಿಯನ್ನು ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು & ನೈರ್ಮಲ್ಯ ವಿಭಾಗ ಬೆಳಗಾವಿ

ಪ್ರಯೋಗಾಲಯದಿಂದ ಪರಿಶೀಲಿಸಿ ಈ ಕಛೇರಿಗೆ ಸಲ್ಲಿಸಿರುತ್ತೀರಿ. ಸದರ ವರದಿಯ ಪ್ರಕಾರ ಕುಡಿಯುವ ನೀರಿನ ಎಲ್ಲ

ಅಂಶಗಳು ಐಎಸ್ 3025 ರ ಸಾಮಾನ್ಯ ಮಿತಿಯಲ್ಲಿ ಇರುತ್ತವೆ. ಅದರಿಂದ ಸದರಿ ಶಾಲೆಯ ನೀರು ಕುಡಿಯಲು

ಯೋಗ್ಯವಿರುತ್ತದೆ ಎಂದು ತಮ್ಮ ಮಾಹಿತಿಗಾಗಿ ಸಲ್ಲಿಸಲಾಗಿದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಅಭಿಯಂತರರು

ಗ್ರಾ.ಕು.ನೀ & ನೈ ಉಪ ವಿಭಾಗ, ಖಾನಾಪೂರ

ಗ್ರಾ.ಕು.ನೀ & ನೈ ಉಪ ವಿಭಾಗ

ಖಾನಾಪೂರ